

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/2022/SZ/ 913

Dated: 26 / 8 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **BLUE BELLS SCHOOL INTERNATIONAL** at Kailash, New Delhi 110048 comprised of Basement, Ground plus three upper Floors owned/occupied by **Blue Bells Education Society** was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2005/2000 Dated 28/09/2005. The said premises was re-inspected by officer concerned of this department on 18/08/2022 in presence of Mrs. Manju Sethi and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 26 / 08 / 2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 26 / 8 / 2022 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to: -

1. M/s BLUE BELLS SCHOOL INTERNATIONAL (Blue Bells Education Society) at Kailash, New Delhi 110048.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
3. The Joint Director (R&E), DDA, Building Section, Vikas Sadan, INA, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. In any case, the Additional / temporary rooms at 3rd floor of the building shall not be used for conducting classes and or any other educational activities, as undertaking submitted by the school management